



Product Service

Attestation of Conformity

No. N8A 104991 0005 Rev. 03

Holder of Attestation: Q-SUN Anhui Co., Ltd.

West of Jingliu Road, North of Weisan Road
239300 Tianchang City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.:

704062115003-04

Date, 2023-09-15

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

Attestation of Conformity

No. N8A 104991 0005 Rev. 03

Model(s):

QN-xxxHF, xxx = 630 to 660 in steps of 5
 QN-xxxHF, xxx = 580 to 600 in steps of 5
 QN-xxxHC, xxx = 540 to 560 in steps of 5
 QN-xxxHC-1, xxx = 540 to 560 in steps of 5
 QN-xxxHC, xxx = 495 to 510 in steps of 5
 QN-xxxHC-1, xxx = 495 to 510 in steps of 5
 QN-xxxHC, xxx = 450 to 465 in steps of 5
 QN-xxxHC-1, xxx = 450 to 465 in steps of 5
 QN-xxxHC, xxx = 400 to 420 in steps of 5
 QN-xxxHC-1, xxx = 400 to 420 in steps of 5
 QN-xxxHD, xxx = 560 to 600 in steps of 5
 QN-xxxHD-1, xxx = 560 to 600 in steps of 5
 QN-xxxHD, xxx = 515 to 550 in steps of 5
 QN-xxxHD-1, xxx = 515 to 550 in steps of 5
 QN-xxxHD, xxx = 470 to 500 in steps of 5
 QN-xxxHD-1, xxx = 470 to 500 in steps of 5
 QN-xxxHD, xxx = 420 to 450 in steps of 5
 QN-xxxHD-1, xxx = 420 to 450 in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

